



ENGINE HALL & UTILITY BLOCK						MECHANICAL UTILITY AREA									
ITEM NO	PCS.	CODE (FIRST)	DESCRIPTION	WEIGHT INCL. LIQUIDS KG	WEIGHT INCL. LIQUIDS LB	MOUNTING LEVEL MILLIM.	(FLR LEVEL) INCH.	ITEM NO	PCS.	CODE (FIRST)	DESCRIPTION	WEIGHT INCL. KG	LIQUIDS LBS	MOUNTING LEVEL MILLIM.	INCH.
1	14	SOA	ENGINE GENERATOR SET	134700	298692	+0.000	0'-0"	71	42	-	RADIATORS LOW-LOW NOISE RADIATORS	-	-	-	-
4	14	OEA	AUXILIARY MODULE	4200	9259	+0.000	0'-0"	90	14	NHA	EXHAUST GAS SILENCER	5200	11454	+5.560	+22'- 5"
37	14	ZBB	GAS REGULATING UNIT	200	440	+0.000	0'-0"	94	34	NGA	RUPTURE DISC	-	-	-	-
60	2	TCA	WORKING AIR UNIT	670	1477	+0.000	0'-0"	103	14	-	DENOX (SCR)	14000	30864	+5.560	+22'- 5"
62	2	TSB	STARTING AIR UNIT	710	1565	+0.000	0'-0"								
63	4	TSB	STARTING AIR BOTTLE 9.4M3/2500 GAL	4335	9555	+0.000	0'-0"	170	1	-	RAW WATER TANK 35,000 GAL	-	-	-	-
70	2	VBA	MAINTENANCE WATER TANK 4M3/1060GAL	4940	10890	+0.000	0'-0"	172	1	-	FIRE FIGHTING CONTAINER	-	-	-	-
72	14	VEA	EXPANSION VESSEL 600L/160GAL	775	1708	+4.940	16'- 2"	181	2	AET	STEP-UP TRANSFORMER	-	-	-	-
80	14	NGA	CHARGE AIR FILTER	960	2116	+3.100	10'- 2"								
82	14	-	CHARGE AIR & EXHAUST GAS MODULE	3000	6613	+3.240	11'- 2"								
93	14	NHA	EXHAUST GAS VENTILATION UNIT	55	121	+4.940	16'- 2"								
104	14	SEN	DOSING BOX	-	-	+0.000	0'-0"	DAY / STORAGE TANK / UNLOADING AREA							
108	14	SNC	NOX CONTROLLER	-	-	+0.000	0'-0"	ITEM NO	PCS.	CODE (FIRST)	DESCRIPTION	WEIGHT INCL. KG	LIQUIDS LBS	MOUNTING LEVEL MILLIM.	INCH.
182	18	-	MV SWITCHGEAR	-	-	+0.000	0'-0"								
183	14	BAN	NEUTRAL GROUNDING RESISTOR	-	-	+0.000	0'-0"	40	1	QAA	LO UNLOADING PUMP UNIT (CLEAN)	-	-	-	-
185	-	BEY	DC-SYSTEM	-	-	+0.000	0'-0"	42	1	QAC	CLEAN LO TANK 5M3/14531GAL	-	-	-	-
186	-	BFA	LV SWITCHGEAR	-	-	+0.000	0'-0"	43	2	QAD	USED/SERVICE LO TANK 13M3/3434GAL	-	-	-	-
189	2	BER	STATION SERVICE TRANSFORMER	-	-	+0.000	0'-0"	44	2	QAE	LO TRANSFER PUMP UNIT	-	-	-	-
196	14	CPA	CONTROL PANEL COMMON	-	-	+0.000	0'-0"	105	2	-	SCR REGENT TANK 10,000 GAL	-	-	-	-
197	14	CFC	CONTROL PANEL ENGINE WISE	-	-	+0.000	0'-0"	145	1	DDR	DIRTY WATER HOLDING TANK 20M3/5284 GAL	-	-	-	-
210	14	-	VENTILATION UNIT (ENGINEHALL)	2000	4409	-	-								
215	14	-	FREQUENCY CONVERTER	-	-	-	-								
230	-	-	225 KW BLACK START GEN.SET	-	-	-	-								

